

処分した一般廃棄物の各月ごとにおける種類及び数量

(単位 トン)

年 月	種類	処 分 量
令和6年 4月	可燃物	7,864
令和6年 5月		10,218
令和6年 6月		10,529
令和6年 7月		9,660
令和6年 8月		9,579
令和6年 9月		8,699
令和6年 10月		4,762
令和6年 11月		9,700
令和6年 12月		9,844
令和7年 1月		10,245
令和7年 2月		9,668
令和7年 3月		

排ガス測定結果

* 値はすべて酸素12%換算濃度

測定位置: 1号炉煙突

測定日	硫黄酸化物 濃度 (ppm)	塩化水素 濃度 (mg/Nm ³)	窒素酸化物 濃度 (ppm)	ばいじん (g/Nm ³)	報告日
6月24日	7	13	32	0.001未満	7月24日
8月23日	5	16	43	0.001未満	9月27日
1月7日	7	15	37	0.001未満	1月31日

測定位置: 2号炉煙突

測定日	硫黄酸化物 濃度 (ppm)	塩化水素 濃度 (mg/Nm ³)	窒素酸化物 濃度 (ppm)	ばいじん (g/Nm ³)	報告日
4月22日	6	10	31	0.001未満	5月22日
6月24日	5	16	40	0.001未満	7月24日
11月5日	8	38	55	0.001未満	12月5日
1月7日	5	10	33	0.001未満	1月31日

測定位置: 3号炉煙突

測定日	硫黄酸化物 濃度 (ppm)	塩化水素 濃度 (mg/Nm ³)	窒素酸化物 濃度 (ppm)	ばいじん (g/Nm ³)	報告日
5月21日	6	11	33	0.001未満	6月20日
8月23日	6	13	35	0.001未満	9月27日
11月5日	5	12	38	0.001未満	12月5日

ダイオキシン類測定結果

排出ガス

(単位:ng-TEQ/m³N) * 酸素12%換算濃度

	測定日	報告日	測定結果	排出基準
1号炉	9月5日	10月4日	0	1以下
2号炉	5月17日	6月24日	0.000011	
3号炉	9月5日	10月4日	0	

燃え殻(焼却灰)

(単位:ng-TEQ/g)

	1月			
1号炉	0.0098			
2号炉	0.0026			
3号炉	—			

ばいじん

(単位:ng-TEQ/g)

	12月	1月	2月									
薬剤処理後	0.61	0.54	0.38									

排水水

(単位:pg-TEQ/L)

	測定日	報告日	測定結果	排出基準
処理水	5月17日	6月14日	0	10以下

周辺大気

(単位:pg-TEQ/m³)

	5月	8月	11月	2月	平均	環境基準
伊川谷小学校	0.0074	0.0072	0.0070	0.0091	0.008	平均0.6以下

西クリーンセンター南西1400m

[illegible]

	1号炉						2号炉			3号炉			備 考
日	燃烧温度 (℃)		ハグフィルタ 入口温度 (℃)		一酸化炭 素濃度 (ppm)		燃烧温度 (℃)	ハグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	燃烧温度 (℃)	ハグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	
1	停止		停止		停止		964	172	8	停止	停止	停止	
2							980	172	9				
3							984	172	7				
4							978	173	6				
5							969	174	7				
6							990	174	10				
7							959	173	7	↓	↓	↓	
8							953	173	6	982	171	7	
9							956	173	7	992	171	8	
10							955	172	10	1002	171	9	
11							936	172	3	1002	172	5	
12							937	173	5	995	172	7	
13							917	172	6	987	172	4	
14							936	172	5	1000	172	6	
15							925	173	5	984	173	6	
16							921	173	7	998	173	7	
17							918	173	8	994	173	8	
18							916	173	5	996	173	7	
19							922	173	4	989	172	6	
20							914	173	6	981	172	8	
21							914	173	7	991	172	11	
22							905	173	10	982	173	9	
23							914	173	9	989	173	11	
24							918	173	9	995	173	8	
25							934	172	4	997	172	5	
26							910	173	5	974	173	6	
27							915	173	7	974	173	7	
28							909	173	6	977	173	6	
29							913	173	4	980	173	5	
30							902	174	8	984	173	7	
31	↓		↓		↓		912	174	8	985	172	7	

[illegible]

排ガス温度等連続測定記録

	1号炉			2号炉			3号炉			備 考
日	燃烧温度 (℃)	ハグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	燃烧温度 (℃)	ハグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	燃烧温度 (℃)	ハグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	
1	868	171	6	871	169	3	停止	停止	停止	
2	877	171	5	879	169	3				
3	871	172	5	863	169	3				
4	877	171	7	869	169	4				
5	877	171	5	885	169	4				
6	882	171	5	892	169	3				
7	872	170	6	878	169	2				
8	877	170	11	886	169	10				
9	880	170	8	887	168	9				
10	813	165	10	830	164	10				
11	821	163	7	862	161	5				
12	828	160	6	852	157	8				
13	834	159	8	856	157	7				
14	841	159	5	886	156	5				
15	832	159	5	872	156	2				
16	831	159	9	858	156	5				
17	832	160	8	857	157	5				
18	835	159	10	871	156	8				
19	825	159	12	862	156	9				
20	837	160	9	872	156	5				
21	845	160	3	877	156	2				
22	867	165	6	890	163	7				
23	868	165	7	887	164	7				
24	877	165	6	909	163	4				
25	870	165	9	905	163	8				
26	880	165	11	907	163	9				
27	879	165	5	900	164	3				
28	890	166	4	883	164	2				
29	882	166	6	883	164	6				
30	877	166	8	887	164	9				
31	871	165	7	888	164	7	▼	▼	▼	

排ガス温度等連続測定記録

	1号炉			2号炉			3号炉						備 考
日	燃烧温度 (℃)	ハグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	燃烧温度 (℃)	ハグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	燃烧温度 (℃)	ハグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)				
1	886	164	6	883	164	8	停止		停止		停止		
2	890	164	7	886	164	7							
3	894	163	5	904	164	5							
4	862	164	4	889	164	3							
5	866	165	6	887	164	8							
6	878	165	8	893	164	8							
7	882	166	5	903	164	4							
8	892	165	8	898	164	7							
9	888	165	5	900	164	7							
10	889	165	5	916	163	4							
11	874	166	4	889	164	5							
12	890	165	6	899	163	6							
13	897	165	4	901	163	6							
14	891	165	4	904	163	2							
15	890	165	5	917	162	4							
16	902	165	6	907	163	8							
17	877	165	5	905	163	2							
18	866	165	4	888	163	6							
19	876	164	8	892	163	9							
20	844	161	6	866	161	5	▼		▼		▼		
21	853	164	7	停止	停止	停止	870		168		23		
22	873	165	6				870		169		23		
23	875	165	6				910		168		20		
24	871	165	4				908		168		13		
25	857	165	6				895		169		10		
26	820	157	15				871		161		16		
27	853	156	11				865		161		15		
28	826	157	16				875		160		22		
29	850	158	10				897		159		18		
30	858	158	11				906		161		13		
31	851	158	5	▼	▼	▼	913		160		7		

排ガス温度等連続測定記録

	1号炉			2号炉				3号炉			備 考
日	燃烧温度 (℃)	バグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	燃烧温度 (℃)	バグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)		燃烧温度 (℃)	バグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	
1	845	158	4	停止		停止		909	162	7	
2	842	158	5					893	163	10	
3	842	157	9					894	163	17	
4	854	157	6					900	163	14	
5	856	157	8					926	163	7	
6	858	157	8					916	163	11	
7	834	158	4					895	163	5	
8	828	158	4					899	163	5	
9	831	158	6					910	162	13	
10	835	158	11					908	163	13	
11	847	158	7					910	162	13	
12	854	157	8					915	160	13	
13	854	158	9					904	162	16	
14	840	158	6					883	163	10	
15	825	158	7					894	161	7	
16	860	164	7					913	168	9	
17	869	164	11					916	168	15	
18	878	168	7					935	172	14	
19	887	169	4					945	172	9	
20	888	170	6					955	173	12	
21	860	171	6					941	173	13	
22	847	171	4					939	173	7	
23	865	170	7					952	172	9	
24	868	170	10					956	172	14	
25	880	170	6					962	172	14	
26	872	170	9					977	171	15	
27	867	170	11					977	171	18	
28	872	170	7					977	171	10	
29	867	170	5					977	169	6	
30	873	170	11					973	169	12	
				▼	▼		▼				

排ガス温度等連続測定記録

	1号炉			2号炉			3号炉			備 考
日	燃烧温度 (℃)	ハグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	燃烧温度 (℃)	ハグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	燃烧温度 (℃)	ハグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	
1	880	170	8	停止	停止	停止	975	171	11	
2	867	170	9				980	172	15	
3	863	170	5				952	172	9	
4	865	170	5				966	172	7	
5	866	170	5				960	171	7	
6	860	170	7				966	172	10	
7	870	171	6				968	172	8	
8	869	171	8				979	172	11	
9	875	171	6				991	172	9	
10	877	171	8				988	172	11	
11	883	170	7				988	171	12	
12	880	171	5				988	173	6	
13	停止	停止	停止				停止	停止	停止	
14										
15										
16										
17										
18										
19										
20										
21										
22										
23										
24										
25										
26										
27										
28										
29										
30				↓	↓	↓	↓	↓	↓	
31	↓	↓	↓	860	170	24	965	168	5	

排ガス温度等連続測定記録

[illegible]

排ガス温度等連続測定記録

	1号炉			2号炉			3号炉			備 考
日	燃烧温度 (℃)	ハグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	燃烧温度 (℃)	ハグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	燃烧温度 (℃)	ハグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	
1	停止	停止	停止	907	172	9	961	169	9	
2				912	172	8	968	170	7	
3				918	172	7	971	170	6	
4				913	172	8	962	172	8	
5				924	171	7	968	171	6	
6				931	171	6	981	171	7	
7				926	171	5	990	171	6	
8				940	171	6	985	172	9	
9				935	170	8	985	169	8	
10				935	170	8	971	168	8	
11				920	170	7	973	168	8	
12				901	171	8	972	170	9	
13				921	171	12	969	171	11	
14				922	171	5	974	171	6	
15				921	172	5	967	171	10	
16				923	171	7	983	169	7	
17				924	170	10	991	168	11	
18				920	170	9	983	168	10	
19				935	169	11	981	167	10	
20				936	170	8	991	168	9	
21				934	171	6	984	167	7	
22				920	171	4	972	167	6	
23				935	170	10	976	163	10	
24	▼	▼	▼	903	166	5	959	155	5	
25	864	168	24	894	171	6	停止	停止	停止	
26	850	170	28	917	171	8				
27	停止	停止	停止	959	173	12				
28	▼	▼	▼	978	173	5				
29	▼	▼	▼	959	171	7				
30	897	169	32	964	169	7	▼	▼	▼	
31	897	167	51	958	169	8	▼	▼	▼	

排ガス温度等連続測定記録

	1号炉			2号炉			3号炉			備 考
日	燃烧温度 (℃)	バグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	燃烧温度 (℃)	バグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	燃烧温度 (℃)	バグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	
1	886	168	35	951	168	8	停止	停止	停止	
2	899	168	25	972	168	8				
3	887	168	9	961	169	4				
4	879	169	7	924	170	3				
5	892	169	7	929	169	3				
6	875	169	8	917	170	4				
7	896	168	8	940	170	4				
8	883	168	8	946	170	5				
9	881	167	9	935	170	4				
10	894	167	7	927	169	5				
11	895	167	6	929	170	3				
12	880	167	4	918	170	3				
13	902	166	5	939	170	2				
14	907	166	5	910	171	7				
15	890	166	7	918	170	6				
16	909	166	4	924	170	4				
17	880	166	6	918	170	6				
18	921	165	3	928	170	4				
19	917	165	4	938	170	3				
20	912	166	6	939	170	8				
21	907	165	6	927	170	4				
22	904	165	4	930	170	3				
23	906	165	5	930	170	5				
24	913	166	5	931	170	4				
25	920	165	2	956	170	2				
26	903	165	3	937	170	3				
27	892	167	6	918	171	6				
28	901	166	6	927	170	7				
29	895	166	6	905	171	5				
30	921	166	5	924	170	5				
31	912	166	4	921	170	6	▼	▼	▼	

排ガス温度等連続測定記録

	1号炉			2号炉			3号炉						備 考
日	燃烧温度 (℃)	パグフィルタ 入口温度 (℃)	一酸化炭素濃度 (ppm)	燃烧温度 (℃)	パグフィルタ 入口温度 (℃)	一酸化炭素濃度 (ppm)	燃烧温度 (℃)		パグフィルタ 入口温度 (℃)		一酸化炭素濃度 (ppm)		
1	924	168	5	939	169	5	停止		停止		停止		
2	911	168	3	943	170	4							
3	893	168	5	929	170	9							
4	904	167	5	928	170	9							
5	907	167	3	923	171	8							
6	914	167	5	929	170	6							
7	908	167	6	913	169	8							
8	911	166	4	916	170	6							
9	904	166	4	923	169	5							
10	901	166	5	913	170	8							
11	910	166	3	930	169	5							
12	900	168	4	919	169	6							
13	913	167	6	934	170	8							
14	912	167	8	922	170	7							
15	904	167	2	923	170	4							
16	891	168	3	915	171	4							
17	924	167	4	930	165	6							
18	894	160	4	895	158	6							
19	907	164	5	停止	停止	停止	957		167		10		
20	897	166	5				967		169		8		
21	900	165	6				986		169		8		
22	918	165	4				998		168		7		
23	894	166	3				995		169		7		
24	896	166	4				1000		167		7		
25	905	165	6				1003		167		12		
26	894	166	4				993		168		8		
27	897	166	6				1001		168		7		
28	922	167	4				1007		167		7		

日	1号炉			2号炉				3号炉			備 考
	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)		硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	
1	8	12	41	停止		停止		8	12	39	
2	8	9	40					8	10	40	
3	8	10	40					8	10	39	
4	8	11	41					7	10	40	
5	8	10	40					8	10	40	
6	8	11	41					8	11	40	
7	8	11	40					7	10	40	
8	7	12	40					7	10	40	
9	7	11	40					8	11	41	
10	8	10	40					7	10	40	
11	7	11	40					7	10	40	
12	8	11	39					7	12	39	
13	7	12	40					7	11	40	
14	7	11	41					7	10	39	
15	8	11	40					8	10	39	
16	8	11	40	↓	↓	↓		停止	停止	停止	
17	停止	停止	停止	9	8	42					
18				9	8	39					
19				9	9	39					
20				9	9	40					
21				9	9	41					
22				8	9	38					
23				8	10	41					
24				8	9	39					
25				8	9	40					
26				8	9	40					
27				8	10	40					
28				8	11	40					
29				8	10	40					
30	↓	↓	↓	8	9	41		↓	↓	↓	
31											

排ガス連続測定記録

日	1号炉			2号炉			3号炉			備 考
	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	
1	停止	停止	停止	8	10	40	停止	停止	停止	
2				8	9	40				
3				8	10	40				
4				8	10	39				
5				8	9	41				
6				9	8	41				
7				8	10	42	↓	↓	↓	
8				8	9	40	8	11	37	
9				8	10	40	8	11	40	
10				8	10	40	8	11	39	
11				8	11	41	8	12	40	
12				8	10	39	8	11	39	
13				6	11	41	7	12	41	
14				6	12	41	7	12	41	
15				7	12	41	7	13	39	
16				7	12	39	7	12	40	
17				7	11	41	7	12	40	
18				8	12	41	8	12	40	
19				7	11	40	8	12	39	
20				7	11	40	8	12	40	
21				7	11	39	7	11	40	
22				7	12	39	7	11	39	
23				7	11	40	7	11	40	
24				7	12	40	8	13	41	
25				8	13	40	8	12	39	
26				7	12	39	7	11	39	
27				6	11	40	6	11	40	
28				6	12	40	7	12	40	
29				7	12	41	7	12	41	
30				6	12	40	6	12	41	
31	↓	↓	↓	7	12	41	7	12	39	

[illegible]

排ガス連続測定記録

日	1号炉			2号炉			3号炉			備 考
	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	
1	6	11	40	4	9	40	停止	停止	停止	
2	5	12	39	4	9	40				
3	6	13	39	5	10	40				
4	6	13	40	5	11	41				
5	6	13	40	6	10	41				
6	7	13	41	6	11	42				
7	7	13	41	6	11	41				
8	6	11	39	6	9	39				
9	6	12	41	6	9	41				
10	6	12	34	6	9	39				
11	5	9	39	6	8	41				
12	4	9	40	3	6	41				
13	6	10	41	5	7	40				
14	6	10	42	6	7	41				
15	5	10	40	5	7	40				
16	5	10	39	3	6	40				
17	6	10	41	4	5	41				
18	5	9	39	4	6	40				
19	5	10	40	4	7	40				
20	6	11	41	6	8	40				
21	6	12	40	5	8	39				
22	5	11	38	5	9	39				
23	5	12	40	5	10	39				
24	7	13	40	7	11	40				
25	5	11	39	5	9	40				
26	6	12	39	6	10	40				
27	7	13	40	6	11	40				
28	7	12	39	7	11	38				
29	6	12	39	6	10	40				
30	6	12	39	6	11	39				
31	5	11	38	6	9	40	▼	▼	▼	

排ガス連続測定記録

日	1号炉			2号炉			3号炉			備 考
	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	
1	6	11	39	6	10	38	停止	停止	停止	
2	5	10	40	6	10	40				
3	7	11	40	7	11	39				
4	6	11	39	6	11	40				
5	5	11	40	5	10	40				
6	7	12	40	6	10	41				
7	6	11	40	6	11	39				
8	6	11	39	6	10	40				
9	6	12	40	6	10	39				
10	7	12	42	7	11	41				
11	7	12	37	7	10	40				
12	6	12	41	7	10	40				
13	7	11	40	7	10	40				
14	7	11	39	7	11	41				
15	7	12	38	7	10	40				
16	7	12	36	7	10	40				
17	7	11	38	7	11	41				
18	7	11	40	7	10	39				
19	6	12	35	7	10	39				
20	5	11	35	6	10	42	▼	▼	▼	
21	5	11	45	停止	停止	停止	8	9	41	
22	5	11	39				8	9	40	
23	6	11	41				8	9	40	
24	6	12	39				8	9	41	
25	6	11	39				8	9	40	
26	3	6	37				6	7	38	
27	5	7	42				7	8	41	
28	6	9	39				7	8	38	
29	5	8	40				6	8	40	
30	5	9	41				6	8	40	
31	6	11	40	▼	▼	▼	6	8	39	

日	1号炉			2号炉						3号炉			備 考
	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)				
1	6	9	39	停止		停止		停止		7	8	40	
2	5	9	40							6	8	39	
3	5	9	40							6	8	38	
4	6	9	40							6	8	41	
5	6	9	40							6	7	39	
6	6	9	40							6	7	40	
7	6	10	39							6	8	40	
8	6	10	41							6	8	40	
9	5	9	40							6	8	40	
10	5	9	40							6	8	40	
11	5	9	40							6	8	40	
12	5	9	40							6	8	41	
13	5	9	40							6	8	40	
14	6	10	39							7	8	36	
15	6	10	39							6	9	39	
16	6	13	38							7	11	40	
17	6	12	40							7	11	40	
18	7	12	40							8	10	40	
19	7	12	41							8	10	40	
20	7	12	39							8	11	40	
21	7	13	39							8	10	40	
22	7	12	40							7	10	39	
23	6	13	39							7	12	41	
24	6	12	40							7	11	40	
25	7	12	38							8	10	40	
26	7	12	41							8	10	40	
27	7	12	40							8	10	39	
28	7	13	40							9	11	42	
29	8	11	39							8	10	40	
30	6	11	39							8	10	41	
				▼	▼	▼							

排ガス連続測定記録

日	1号炉			2号炉						3号炉			備 考
	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	
1	6	12	41	停止	停止	停止	7	10	41				
2	7	12	40				8	10	39				
3	6	11	40				7	10	40				
4	6	12	40				7	11	41				
5	6	13	38				8	12	40				
6	6	11	40				8	10	41				
7	5	11	39				7	11	40				
8	6	13	40				7	11	40				
9	7	13	41				7	11	41				
10	6	13	39				7	11	39				
11	6	11	41				7	11	41				
12	7	14	42				8	14	40				
13	停止	停止	停止				停止	停止	停止				
14													
15													
16													
17													
18													
19													
20													
21													
22													
23													
24													
25													
26													
27													
28													
29													
30				↓	↓	↓	↓	↓	↓				
31	↓	↓	↓	8	12	44	7	11	28				

日	1号炉						2号炉			3号炉			備 考
	硫黄酸化 物濃度 (ppm)		塩化水 素濃度 (ppm)		窒素酸化 物濃度 (ppm)		硫黄酸化 物濃度 (ppm)		塩化水 素濃度 (ppm)		窒素酸化 物濃度 (ppm)		
1	停止		停止		停止		8	12	37	7	11	41	
2							8	12	41	7	12	40	
3							8	11	41	7	11	40	
4							8	11	41	7	12	41	
5							8	11	40	7	12	41	
6							8	9	40	7	11	40	
7							8	9	41	8	10	42	
8							8	9	40	8	10	41	
9							8	10	39	7	11	40	
10							8	9	40	8	9	40	
11							8	10	40	7	11	41	
12							8	9	39	8	11	42	
13							8	10	40	7	12	40	
14							8	10	38	7	11	42	
15							7	10	40	8	10	40	
16							8	10	41	8	12	39	
17							8	9	41	8	11	40	
18							7	10	40	7	11	41	
19							7	10	40	8	11	42	
20							7	9	40	7	11	37	
21							7	9	41	7	10	39	
22							8	10	40	7	10	39	
23							8	9	41	8	10	41	
24							7	10	41	7	11	40	
25							7	9	39	7	10	39	
26							7	9	39	7	10	41	
27							8	11	40	7	11	39	
28							7	11	40	6	11	40	
29							7	10	41	7	12	40	
30		▼		▼		▼	7	11	40	7	12	40	

排ガス連続測定記録

日	1号炉			2号炉			3号炉			備 考
	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	
1	停止	停止	停止	8	10	39	8	11	41	
2				7	10	40	6	11	40	
3				7	11	39	7	12	39	
4				7	11	38	7	12	39	
5				7	11	40	7	11	40	
6				7	11	41	7	11	39	
7				7	13	41	7	13	40	
8				7	11	40	8	10	40	
9				7	10	40	7	10	41	
10				7	10	40	7	10	40	
11				7	11	39	7	10	38	
12				7	10	40	7	10	39	
13				7	9	41	7	10	41	
14				8	11	40	7	10	40	
15				8	11	41	8	10	39	
16				7	11	41	7	10	40	
17				7	11	40	7	10	40	
18				8	12	40	8	11	41	
19				7	11	40	7	10	39	
20				7	11	40	7	11	41	
21				8	12	41	7	12	39	
22				7	12	40	7	11	39	
23				7	11	41	7	11	40	
24	↓	↓	↓	7	9	41	6	8	40	
25	8	9	34	7	12	40	停止	停止	停止	
26	9	10	40	7	12	40				
27	停止	停止	停止	9	12	40				
28				8	13	40				
29	↓	↓	↓	8	12	40				
30	9	9	38	8	10	42				
31	9	8	37	9	10	38	↓	↓	↓	

排ガス連続測定記録

日	1号炉			2号炉			3号炉			備 考
	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	
1	9	7	39	8	10	40	停止	停止	停止	
2	9	7	39	8	10	41				
3	8	8	40	7	11	39				
4	7	11	40	6	13	39				
5	8	10	40	7	12	39				
6	7	11	40	5	11	40				
7	7	11	41	6	11	41				
8	8	11	40	7	11	41				
9	7	12	40	7	12	40				
10	7	12	40	7	11	41				
11	8	12	40	7	12	40				
12	8	11	39	7	11	40				
13	7	12	40	7	12	41				
14	7	11	41	6	12	41				
15	7	12	39	7	12	40				
16	7	11	40	7	12	39				
17	7	13	39	6	11	40				
18	7	14	40	7	13	39				
19	7	12	40	7	13	40				
20	7	13	39	7	12	41				
21	7	13	41	7	13	41				
22	8	13	40	7	12	40				
23	7	11	39	6	11	40				
24	7	11	40	6	11	41				
25	8	13	41	7	12	40				
26	7	12	39	7	12	40				
27	6	12	38	6	11	39				
28	7	13	40	7	12	40				
29	7	13	41	6	13	39				
30	7	11	41	7	13	40				
31	7	12	39	6	11	40	↓	↓	↓	

[illegible]

冷却設備及びガス処理設備に堆積したばいじんの除去を行った年月日

西クリーンセンター

令和6年4月

冷 却 設 備				ガス処理設備			
除 去 方 法				除 去 方 法			
日	1号炉	2号炉	3号炉	日	1号炉	2号炉	3号炉
1	①	停止	①	1	①	停止	①
2	①		①	2	①		①
3	①		①	3	①		①
4	①		①	4	①		①
5	①		①	5	①		①
6	①		①	6	①		①
7	①		①	7	①		①
8	①		①	8	①		①
9	①		①	9	①		①
10	①		①	10	①		①
11	①		①	11	①		①
12	①		①	12	①		①
13	①		①	13	①		①
14	①		①	14	①		①
15	①		①	15	①		①
16	①	↓	停止	16	①	↓	停止
17	停止	①		17	停止	①	
18		①		18		①	
19		①		19		①	
20		①		20		①	
21		①		21		①	
22		①		22		①	
23		①		23		①	
24	②	①		24	②	①	
25		①		25		①	
26		①		26		①	
27		①		27		①	
28		①		28		①	
29	②	①		29		①	
30	②↓	①	↓	30	↓	①	↓
31				31			
(※) ① スートブローによる除去 (毎日実行) ② 休炉点検時における除去				(※) ① バグフィルターの逆洗による除去 (毎日実行) ② 休炉点検時における除去			

冷却設備及びガス処理設備に堆積したばいじんの除去を行った年月日

西クリーンセンター

令和6年5月

冷 却 設 備				ガス処理設備			
除 去 方 法				除 去 方 法			
日	1号炉	2号炉	3号炉	日	1号炉	2号炉	3号炉
1	停止	①	停止	1	停止	停止	停止
2		①		2		①	
3		①	②	3		①	
4		①		4		①	
5		①		5		①	
6		①		6		①	
7		①	↓	7	②	①	↓
8		①	①	8	②	①	①
9		①	①	9		①	①
10		①	①	10		①	①
11		①	①	11		①	①
12		①	①	12		①	①
13		①	①	13		①	①
14		①	①	14		①	①
15		①	①	15		①	①
16		①	①	16		①	①
17		①	①	17		①	①
18		①	①	18		①	①
19		①	①	19		①	①
20		①	①	20		①	①
21		①	①	21		①	①
22		①	①	22		①	①
23		①	①	23		①	①
24		①	①	24		①	①
25		①	①	25		①	①
26		①	①	26		①	①
27		①	①	27		①	①
28		①	①	28		①	①
29		①	①	29		①	①
30		①	①	30		①	①
31	↓	①	①	31	↓	①	①
(※) ① スートブローによる除去 (毎日実行) ② 休炉点検時における除去				(※) ① バグフィルターの逆洗による除去 (毎日実行) ② 休炉点検時における除去			

冷却設備及びガス処理設備に堆積したばいじんの除去を行った年月日

西クリーンセンター

令和6年6月

冷 却 設 備				ガス処理設備			
除 去 方 法				除 去 方 法			
日	1号炉	2号炉	3号炉	日	1号炉	2号炉	3号炉
1	停止	①	①	1	停止	停止	①
2		①	①	2		①	①
3		①	①	3		①	①
4		①	①	4		①	①
5		①	①	5		①	①
6		①	①	6		①	①
7		①	①	7		①	①
8		①	①	8		①	①
9		①	①	9		①	①
10		①	①	10		①	①
11		①	①	11		①	①
12		①	①	12		①	①
13		①	①	13		①	①
14		①	①	14		①	①
15		①	①	15		①	①
16		①	①	16		①	①
17		①	①	17		①	①
18	↓	①	①	18	↓	①	①
19	①	①	停止	19	①	①	停止
20	①	①		20	①	①	
21	①	①		21	①	①	
22	①	①		22	①	①	
23	①	①		23	①	①	
24	①	①		24	①	①	
25	①	①		25	①	①	
26	①	①	②	26	①	①	
27	①	①		27	①	①	
28	①	①		28	①	①	②
29	①	①		29	①	①	
30	①	①		30	①	①	
31	①	①	↓	31	①	①	↓
(※) ① スートブローによる除去 (毎日実行) ② 休炉点検時における除去				(※) ① バグフィルターの逆洗による除去 (毎日実行) ② 休炉点検時における除去			

冷却設備及びガス処理設備に堆積したばいじんの除去を行った年月日

西クリーンセンター

令和6年7月

冷 却 設 備				ガス処理設備			
除 去 方 法				除 去 方 法			
日	1号炉	2号炉	3号炉	日	1号炉	2号炉	3号炉
1	①	①	停止	1	①	①	停止
2	①	①		2	①	①	
3	①	①		3	①	①	
4	①	①		4	①	①	
5	①	①		5	①	①	
6	①	①		6	①	①	
7	①	①		7	①	①	
8	①	①	②	8	①	①	
9	①	①	②	9	①	①	
10	①	①		10	①	①	
11	①	①		11	①	①	
12	①	①		12	①	①	
13	①	①		13	①	①	
14	①	①		14	①	①	
15	①	①		15	①	①	②
16	①	①		16	①	①	②
17	①	①		17	①	①	
18	①	①		18	①	①	
19	①	①		19	①	①	
20	①	①		20	①	①	
21	①	①		21	①	①	
22	①	①		22	①	①	
23	①	①		23	①	①	
24	①	①		24	①	①	
25	①	①		25	①	①	
26	①	①		26	①	①	
27	①	①		27	①	①	
28	①	①		28	①	①	
29	①	①		29	①	①	
30	①	①		30	①	①	
31	①	①	↓	31	①	①	↓
(※) ① スートブローによる除去 (毎日実行) ② 休炉点検時における除去				(※) ① バグフィルターの逆洗による除去 (毎日実行) ② 休炉点検時における除去			

冷却設備及びガス処理設備に堆積したばいじんの除去を行った年月日

西クリーンセンター

令和6年8月

冷 却 設 備				ガス処理設備			
除 去 方 法				除 去 方 法			
日	1号炉	2号炉	3号炉	日	1号炉	2号炉	3号炉
1	①	①	停止	1	①	①	停止
2	①	①		2	①	①	
3	①	①		3	①	①	
4	①	①		4	①	①	
5	①	①		5	①	①	
6	①	①		6	①	①	
7	①	①		7	①	①	
8	①	①		8	①	①	
9	①	①		9	①	①	
10	①	①		10	①	①	
11	①	①		11	①	①	
12	①	①		12	①	①	
13	①	①		13	①	①	
14	①	①		14	①	①	
15	①	①		15	①	①	
16	①	①		16	①	①	
17	①	①		17	①	①	
18	①	①		18	①	①	
19	①	①		19	①	①	
20	①	①	↓	20	①	①	↓
21	①	停止	①	21	①	停止	①
22	①		①	22	①		①
23	①		①	23	①		①
24	①		①	24	①		①
25	①		①	25	①		①
26	①	②	①	26	①		①
27	①	②	①	27	①		①
28	①		①	28	①	②	①
29	①		①	29	①	②	①
30	①		①	30	①		①
31	①	↓	①	31	①	↓	①
(※) ① スートブローによる除去 (毎日実行) ② 休炉点検時における除去				(※) ① バグフィルターの逆洗による除去 (毎日実行) ② 休炉点検時における除去			

冷却設備及びガス処理設備に堆積したばいじんの除去を行った年月日

西クリーンセンター

令和6年9月

冷 却 設 備				ガス処理設備			
	除 去 方 法				除 去 方 法		
日	1号炉	2号炉	3号炉	日	1号炉	2号炉	3号炉
1	①	停止	①	1	①	停止	①
2	①		①	2	①		①
3	①		①	3	①		①
4	①		①	4	①		①
5	①		①	5	①		①
6	①		①	6	①		①
7	①		①	7	①		①
8	①		①	8	①		①
9	①	②	①	9	①		①
10	①	②	①	10	①		①
11	①		①	11	①		①
12	①		①	12	①		①
13	①		①	13	①		①
14	①		①	14	①		①
15	①		①	15	①		①
16	①		①	16	①	②	①
17	①		①	17	①	②	①
18	①		①	18	①	②	①
19	①		①	19	①	②	①
20	①		①	20	①	②	①
21	①		①	21	①		①
22	①		①	22	①		①
23	①		①	23	①		①
24	①		①	24	①		①
25	①		①	25	①		①
26	①		①	26	①		①
27	①		①	27	①		①
28	①		①	28	①		①
29	①		①	29	①		①
30	①	↓	①	30	①	↓	①
31				31			
(※) ① スートブローによる除去 (毎日実行) ② 休炉点検時における除去				(※) ① バグフィルターの逆洗による除去 (毎日実行) ② 休炉点検時における除去			

冷却設備及びガス処理設備に堆積したばいじんの除去を行った年月日

西クリーンセンター

令和6年10月

冷 却 設 備				ガス処理設備			
除 去 方 法				除 去 方 法			
日	1号炉	2号炉	3号炉	日	1号炉	2号炉	3号炉
1	①	停止	①	1	①	停止	①
2	①		①	2	①		①
3	①		①	3	①		①
4	①		①	4	①		①
5	①		①	5	①		①
6	①		①	6	①		①
7	①		①	7	①		①
8	①		①	8	①		①
9	①		①	9	①		①
10	①		①	10	①		①
11	①		①	11	①		①
12	①		①	12	①		①
13	停止		停止	13	停止		停止
14				14			
15				15			
16				16			
17				17			
18				18			
19				19			
20				20			
21			②	21			
22				22			②
23				23			②
24				24			②
25				25			
26				26			
27				27			
28	②			28			
29	②			29	②		
30	②			30	②		
31	↓	①	①	31	↓	①	①
(※) ① スートブローによる除去 (毎日実行) ② 休炉点検時における除去				(※) ① バグフィルターの逆洗による除去 (毎日実行) ② 休炉点検時における除去			

冷却設備及びガス処理設備に堆積したばいじんの除去を行った年月日

西クリーンセンター

令和6年11月

冷 却 設 備				ガス処理設備			
除 去 方 法				除 去 方 法			
日	1号炉	2号炉	3号炉	日	1号炉	2号炉	3号炉
1	停止	①	①	1	停止	①	①
2		①	①	2		①	①
3		①	①	3		①	①
4		①	①	4		①	①
5		①	①	5		①	①
6		①	①	6		①	①
7		①	①	7		①	①
8		①	①	8		①	①
9		①	①	9		①	①
10		①	①	10		①	①
11		①	①	11		①	①
12		①	①	12		①	①
13		①	①	13		①	①
14		①	①	14		①	①
15		①	①	15		①	①
16		①	①	16		①	①
17		①	①	17		①	①
18		①	①	18	②	①	①
19		①	①	19	②	①	①
20		①	①	20		①	①
21		①	①	21		①	①
22		①	①	22		①	①
23		①	①	23		①	①
24		①	①	24		①	①
25		①	①	25		①	①
26		①	①	26		①	①
27		①	①	27		①	①
28	②	①	①	28		①	①
29	②	①	①	29		①	①
30	▼	①	①	30	▼	①	①
31				31			
(※) ① スートブローによる除去 (毎日実行) ② 休炉点検時における除去				(※) ① バグフィルターの逆洗による除去 (毎日実行) ② 休炉点検時における除去			

冷却設備及びガス処理設備に堆積したばいじんの除去を行った年月日

西クリーンセンター

令和6年12月

冷 却 設 備				ガス処理設備			
除 去 方 法				除 去 方 法			
日	1号炉	2号炉	3号炉	日	1号炉	2号炉	3号炉
1	停止	①	①	1	停止	①	①
2		①	①	2		①	①
3		①	①	3		①	①
4		①	①	4		①	①
5		①	①	5		①	①
6		①	①	6		①	①
7		①	①	7		①	①
8		①	①	8		①	①
9		①	①	9		①	①
10		①	①	10		①	①
11		①	①	11		①	①
12		①	①	12		①	①
13		①	①	13		①	①
14		①	①	14		①	①
15		①	①	15		①	①
16		①	①	16		①	①
17		①	①	17		①	①
18		①	①	18		①	①
19		①	①	19		①	①
20		①	①	20		①	①
21		①	①	21		①	①
22		①	①	22		①	①
23		①	①	23		①	①
24	↓	①	①	24	↓	①	①
25	①	①	停止	25	①	①	停止
26	①	①		26	①	①	
27	停止	①		27	停止	①	
28	↓	①		28	↓	①	
29	↓	①		29	↓	①	
30	①	①		30	①	①	
31	①	①	↓	31	①	①	↓
(※) ① スートブローによる除去 (毎日実行) ② 休炉点検時における除去				(※) ① バグフィルターの逆洗による除去 (毎日実行) ② 休炉点検時における除去			

冷却設備及びガス処理設備に堆積したばいじんの除去を行った年月日

西クリーンセンター

令和7年1月

冷 却 設 備				ガス処理設備			
	除 去 方 法				除 去 方 法		
日	1号炉	2号炉	3号炉	日	1号炉	2号炉	3号炉
1	①	①	停止	1	①	①	停止
2	①	①		2	①	①	
3	①	①		3	①	①	
4	①	①		4	①	①	
5	①	①		5	①	①	
6	①	①	②	6	①	①	
7	①	①		7	①	①	
8	①	①		8	①	①	
9	①	①		9	①	①	
10	①	①		10	①	①	
11	①	①		11	①	①	
12	①	①		12	①	①	
13	①	①		13	①	①	
14	①	①		14	①	①	
15	①	①		15	①	①	
16	①	①	②	16	①	①	②
17	①	①		17	①	①	
18	①	①		18	①	①	
19	①	①		19	①	①	
20	①	①		20	①	①	
21	①	①		21	①	①	
22	①	①		22	①	①	
23	①	①		23	①	①	
24	①	①		24	①	①	
25	①	①		25	①	①	
26	①	①		26	①	①	
27	①	①		27	①	①	
28	①	①		28	①	①	
29	①	①		29	①	①	
30	①	①		30	①	①	
31	①	①	↓	31	①	①	↓
(※) ① スートブローによる除去 (毎日実行) ② 休炉点検時における除去				(※) ① バグフィルターの逆洗による除去 (毎日実行) ② 休炉点検時における除去			

冷却設備及びガス処理設備に堆積したばいじんの除去を行った年月日

西クリーンセンター

令和7年2月

冷 却 設 備				ガス処理設備			
除 去 方 法				除 去 方 法			
日	1号炉	2号炉	3号炉	日	1号炉	2号炉	3号炉
1	①	①	停止	1	①	①	停止
2	①	①		2	①	①	
3	①	①		3	①	①	②
4	①	①		4	①	①	②
5	①	①		5	①	①	
6	①	①		6	①	①	
7	①	①		7	①	①	
8	①	①		8	①	①	
9	①	①		9	①	①	
10	①	①		10	①	①	
11	①	①		11	①	①	
12	①	①		12	①	①	
13	①	①		13	①	①	
14	①	①		14	①	①	
15	①	①		15	①	①	
16	①	①		16	①	①	
17	①	①		17	①	①	
18	①	①	▼	18	①	①	▼
19	①	停止	①	19	①	停止	①
20	①		①	20	①		①
21	①		①	21	①		①
22	①		①	22	①		①
23	①		①	23	①		①
24	①	②	①	24	①		①
25	①		①	25	①		①
26	①		①	26	①		①
27	①		①	27	①		①
28	①	▼	①	28	①	▼	①
29				29			
30				30			
31				31			
(※) ① スートブローによる除去 (毎日実行) ② 休炉点検時における除去				(※) ① バグフィルターの逆洗による除去 (毎日実行) ② 休炉点検時における除去			